

School District No. 20 (Kootenay-Columbia) Radon Testing Results from Interior Health Authority

Testing occurred between Nov and March with results provided to the district on June 10, 2016

Health Canada guidelines say that any areas where samples are between 200 bq/m³ and 600 bq/m³ should be remediated within 2 years

Health Canada guidelines say that any areas where samples are above 600 bq/m³ should be remediated within 1 year

Site	Sample taken location	Avg. Radon Conc. bq/m³
J.L. Webster Elementary School		
	FIRST FLOOR CLASSROOM	16
	FIRST FLOOR CLASSROOM	13
	FIRST FLOOR CLASSROOM	21
	FIRST FLOOR STAFFROOM	28
	FIRST FLOOR CLASSROOM	41
Robson Community School		
	FIRST FLOOR CLASSROOM	50
	FIRST FLOOR CLASSROOM	35
	FIRST FLOOR LIBRARY	40
	FIRST FLOOR OFFICE AREA	31
	FIRST FLOOR CLASSROOM	71
	FIRST FLOOR GYM	114
Rossland Summit School		
	FIRST FLOOR CLASSROOM	9
	FIRST FLOOR CLASSROOM	less than 9
	FIRST FLOOR CLASSROOM	less than 9
	BASEMENT STORAGE AREA	35
Stanley Humphries Secondary School		
	BASEMENT STORAGE AREA	408
	BASEMENT CLASSROOM	81
	FIRST FLOOR CLASSROOM	18
	FIRST FLOOR CLASSROOM	20
	BASEMENT CLASSROOM	178
	BASEMENT CLASSROOM	176
Castlegar Primary Campus		
	FIRST FLOOR CLASSROOM	26
	FIRST FLOOR CLASSROOM	54
	BASEMENT LIBRARY	48
	FIRST FLOOR GYM	62
	BASEMENT COMPUTER LAB	36
	FIRST FLOOR CLASSROOM	31

Fruitvale Elementary School	
FIRST FLOOR CLASSROOM	22
FIRST FLOOR CLASSROOM	12
FIRST FLOOR CLASSROOM	19
FIRST FLOOR CLASSROOM	16
BASEMENT	71

Glenmerry Elementary School	
FIRST FLOOR CLASSROOM	less than 8
FIRST FLOOR CLASSROOM	less than 8
FIRST FLOOR CLASSROOM	111
PORTABLE	less than 8

J. Lloyd Crowe Secondary School	
FIRST FLOOR CLASSROOM	47
FIRST FLOOR CLASSROOM	74
BASEMENT OPEN AREA	142
BASEMENT BOOK ROOM	262
BASEMENT PAPER STORAGE AREA	154
FIRST FLOOR OFFICE	57

Kootenay-Columbia Learning Centre - Castlegar Campus	
FIRST FLOOR CLASSROOM	84
FIRST FLOOR CLASSROOM	164
FIRST FLOOR OFFICE	108
FIRST FLOOR CLASSROOM	198
FIRST FLOOR CLASSROOM	53

Kootenay-Columbia Learning Centre -Trail Campus	
FIRST FLOOR CLASSROOM	29
FIRST FLOOR OFFICE	33
FIRST FLOOR CLASSROOM	39
FIRST FLOOR CLASSROOM	38
FIRST FLOOR CLASSROOM	34
FIRST FLOOR CLASSROOM	37

Kinnaird Elementary School	
FIRST FLOOR LIBRARY	250
FIRST FLOOR CLASSROOM	231
FIRST FLOOR CLASSROOM	231
FIRST FLOOR CLASSROOM	138
FIRST FLOOR CLASSROOM	88
FIRST FLOOR OFFICE	204

Twin Rivers Elementary School

FIRST FLOOR CLASSROOM	26
FIRST FLOOR CLASSROOM	40
FIRST FLOOR LIBRARY	32
FIRST FLOOR CLASSROOM	36
FIRST FLOOR CLASSROOM	41
FIRST FLOOR CLASSROOM	34
FIRST FLOOR STAFFROOM	26
FIRST FLOOR CLASSROOM	23

Maintenance Shop near J.L. Webster

FIRST FLOOR SHOP AREA	37
-----------------------	----