

2009 RADON LEVELS IN SD20 SITES

Health Canada guidelines are that areas tested at 200 to 600 bq/m³ be remediated within 2 years

Health Canada guidelines are that areas tested at over 600 bq/m³ be remediated within 1 year

School	Area	Result in Bq/m ³
Castlegar Maintenance	Office	115
Castlegar Primary School	Basement library	56
Castlegar Primary School	Classroom	33
Castlegar Primary School	Classroom	37
Fruitvale Elementary School	Library	70
Fruitvale Elementary School	Staff room	30
Fruitvale Elementary School	Staff room	52
Glenmerry Elementary School	Classroom	19
Glenmerry Elementary School	Office	37
Kinnaird Elementary School	Classroom	118
Kinnaird Elementary School	Classroom	155
Kinnaird Elementary School	Classroom	118
MacLean Elementary School	Office	33
MacLean Elementary School	Library	41
KCLC - Castlegar	Office	93
KCLC - Castlegar	Classroom	89
Robson Community School	Office	48
Robson Community School	Classroom	52
Rossland Secondary School	Basement classroom	100
Rossland Secondary School	Office	33
Rossland Secondary School	Library	19
KCLC - Trail	Classroom	44
KCLC - Trail	Classroom	30
Warfield Maintenance Shop	Ground level	48
Twin Rivers Elementary School	Staff room	52
Twin Rivers Elementary School	Office	52
Webster Elementary School	Office	48
Stanley Humphries Secondary School	Basement classroom	167
Stanley Humphries Secondary School	Office	85